

Sent to Charles Miller
9/12/12

[Type the document title]

4 - 12'- 2" X 12'- 0" INSULATED OVERHEAD PANEL DOORS.

- DOORS FINISHED TO BE WHITE
- 3 LAYER PANELS STEEL – INSULATION – STEEL.
- SECTIONS ARE 2" THICK SANDWICH CONSTRUCTION CONSISTING OF INTERIOR AND EXTERIOR STEEL SKINS PRESSURE BONDED TO POLYSTYRENE CORE AND THERMALLY BROKEN WITH A CONTINUOUS BEAD OF SILICONE.
- 24 GAUGE (.22" MIN) EXTERIOR, 27 GAUGE (.016" MIN) INTERIOR.
- TONGUE AND GROOVE SECTION JOINT WITH SILICONE FILLED THERMAL BREAK.
- DOOR INSULATION TO HAVE R-VALUE TO BE EQUAL TO OR GREATER THAN 9.1
- 2 OF 4 DOORS TO BE FITTED WITH ONE INTERIOR MOUNTED END STYLE BOLT DOOR LOCK WITH EXTERIOR HANDLES EACH.
- 2 OF 4 DOORS TO BE FITTED WITH ELECTRIC DRAW BAR STYLE DOOR OPENERS WITH 2 REMOTES AND ONE KEY ENTRY PAD EACH. WITH REQUIRED HP FOR LIFTING DOOR.
- 90 MPH WIND CODE SPECS, FULL WEATHER STRIP,
- PAINT, MATERIALS, AND WORKMANSHIP SHALL BE WARRANTIED FOR MIN. 1 YEAR.

DOOR HARDWARE

- BOTTOM ASTRAGAL RETAINER OF EXTRUDED ALUMINUM WITH VINYL ASTRAGAL.
- BOTTOM BRACKET OF 12 GAUGE GALV. STEEL FASTENED WITH (5) #14 X 5/8" SCREWS.
- 13 GAUGE GALV. STEEL STEP PLATE/LIFT HANDLE – MOUNTED TO BOTTOM BRACKET.
- CENTER SUPPORT BRACKET, STD. LIFT CABLE DRUM, #2 END STILE LOCK
- DRAW BAR OPENERS AND DOORS WILL BE EQUIPED WITH SAFETY REVERSE SYSTEMS AND INTERIOR 3 BUTTON CONTROL STATION.
- ADJUSTABLE TOP ROLLER RACKET OF 12 GAUGE GALV. STEEL (4) #14 X 5/8" SCREWS.
- 14 GAUGE HINDGES, 2" COMMERCIAL 10 BALL STEEL ROLLERS IN CASE HARDENED STEEL RACES, 10,000 CYCLE TORSION SPRINGS.
- 2" REVERSE ANGLE TRACK WITH STANDARD RADIUS.
- ELECTRICAL ROUGH IN WILL BE PERFORMED BY THE OWNER.

INSTALLATION TO BE PROVIDED BY SUCCESSFUL BIDDER WITHIN 30 TO 45 DAYS OF NOTIFICATION BY THE OWNER. ALL MATERIALS, EQUIPMENT, LABOR, AND WARRANTIES ARE TO BE INCLUDED IN BID PRICE. LOCATION OF BUILDING IS 301 W. 14TH. ST. CHANUTE, KS. 66720 SOUTH OF KANSAS HIGHWAY PATROL OFFICE. CONTACT PERSON

DOUG VOGEL DIST. SUPERINTENDENT

411 W. 14TH. ST. CHANUTE, KS. 66720

620-431-1000 or 620-433-0431